



CUMBERLAND MUNICIPAL UTILITY

On July 24, 2025 approximately 50 gallons of untreated wastewater overflowed from a sanitary manhole located at the intersection of 3rd Street and Plum Street. The overflow was identified at 11:00 and is believed to have been caused by plugged sewer main

Corrective Actions Taken:

- The overflow was stopped promptly upon discovery.
- The cause of the overflow has been found and jetted.
- No known impacts to nearby surface waters at this time.

- **Contact Information:**

Katie Goin

Cumberland Utility Wastewater

715-822-2595